

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-1501:150 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Edwards Signaling, 90 Fieldstone Ct., Cheshire, CT 06410
Contact: Jewell Micochero (941) 739-4358 FAX (941) 739-4334

DESIGN: Models EGC-VM and EGCF-VM, multiple candela synchronizable strobe lights. The lights are only considered synchronizable when used with Edwards Systems Technology's Models G1M-RM (CSFM Listing No. 7300-1591:201) Sync Module, which may employ Models SIGA-CC1S (CSFM Listing No. 7300-1591:121) Auto-Sync Output Module. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 16-33 VDC/vFWR
Candela: 15cd, 30cd, 75cd, or 95cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For indoor use only and wall or ceiling mount.

MARKING: Listee's name, model number, electrical/candela rating, and UL label.

APPROVAL: Listed as strobe lights for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

XLF: 7125-1591:219

03-01-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

MARCH 1, 2004

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager